



LEAD IN POTABLE WATER SCREENING REPORT

INVESTIGATION FOR: Tom Wiggins
South Plainfield Township Board of Education
165 Jackson Avenue
South Plainfield, NJ 07080

SITE INVESTIGATED: Grant School
305 Cromwell Place
South Plainfield, NJ 07080

ASSESSMENT BY: Kyle Brown
Omega Environmental Services, Inc.
280 Huyler Street
South Hackensack, NJ 07606

**INVESTIGATION
CONDUCTED:** 11/11/16

DATE OF REPORT: 12/12/16

(Omega Project # 16-27004B)

TABLE OF CONTENTS

EXECUTIVE SUMMARY/PROJECT OVERVIEW

- 1. RESULTS TABLE**
- 2. SAMPLING METHODOLOGY**
- 3. DISCUSSION OF RESULTS**
- 4. RECOMMENDATIONS**

Appendices:

A. Laboratory Analytical Reports

EXECUTIVE SUMMARY:

The South Plainfield Township Board of Education requested lead in water testing of potable water outlets at Grant School, 305 Cromwell Place, South Plainfield, NJ 07080.

Previous Testing

No information related to previous testing was available.

Recent Testing (11/11/16)

In order to assess the building water outlets, a full testing of all potable outlets was performed on November 11, 2016.

Reportedly the outlets were not flushed or used on the day of testing.

First draw and flush samples (30 second) were collected of 15 water fountains and sinks.

All results were below the Lead and Copper action level of 15 ppb.

See Section 3 Discussion of Results

1 RESULTS TABLE:

Sample #	Location	1 st draw (FD) or flush (FL)	Results (ppb)	LCR Action Level ⁽¹⁾ (ppb)
1	At Room 12 – Left	FD	<1.0	15
2	At Room 12 – Right	FD	<1.0	15
3	At Room 17	FD	<1.0	15
4	At Room 30 – Left	FD	<1.0	15
5	At Room 30 – Right	FD	9.0	15
6	Kitchen – Left	FD	5.1	15
7	Kitchen – Right	FD	11.5	15
8	At Gym – Left	FD	1.5	15
9	At Gym – Right	FD	<1.0	15
10	At Principal	FD	<1.0	15
11	Nurse’s Office	FD	3.0	15
12	Nurse’s Office (Lavatory)	FD	2.8	15
13	Faculty Room	FD	<1.0	15
14	At Room 65 – Left	FD	Out of Order	15
15	At Room 65 – Right	FD	Out of Order	15
16	At Room 69	FD	<1.0	15
17	At Room 48	FD	<1.0	15
18	Field Blank	FD	<1.0	15

⁽¹⁾ EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

FL – Flush Sample (30 sec)

NA – Not Analyzed

2 SAMPLING METHODOLOGY:

First Draw Samples - Without allowing any water to spill until sample collection, samples were collected with a relatively slow flow rate in 250 mL bottles prepared with Nitric Acid (HNO₃) as a preservative.

Flush Samples – After collection of first draw samples the water was allowed to flow at a relatively slow rate for thirty second to flush the fixture and close piping. The flush samples are intended to test the plumbing further upstream from the fixture (behind walls).

The samples were packaged in a cooler and shipped to Pace Analytical, Melville, NY for total lead in potable water analysis (method E200.8 IOC).

3 DISCUSSION OF RESULTS:

All lead in water results were below the EPA Lead and Copper action level of 15 ppb. No analysis was performed for copper in water.

4 RECOMMENDATIONS:

Short term:

- No further action is recommended in regards to outlets test

A. Lead in Water Laboratory Reports

November 22, 2016

Emma Moody
Omega Environmental Services
280 Huyler Street
South Hackensack, NJ 07606

RE: Project: SP BOE GRANT SCHOOL 16-27004B
Pace Project No.: 704710


Dear Emma Moody:

Enclosed are the analytical results for sample(s) received by the laboratory on November 12, 2016. The results relate only to the samples included in this report. Results reported herein conform to the most current, applicable TNI/NELAC standards and the laboratory's Quality Assurance Manual, where applicable, unless otherwise noted in the body of the report.

Samples, in the electronic data deliverable (EDD) that accompanied this report, were flagged yellow if they exceeded the NYSDOH 15 ppb action level.

If you have any questions concerning this report, please feel free to contact me.

Sincerely,



Elizabeth Harrison
betty.harrison@pacelabs.com
Project Manager

Enclosures

cc: David Ekstrand, Omega Environmental Services
Michael Levay, Omega Environmental Services
Ray, Omega Environmental Services
Reports
Reports, Omega Environmental Services



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CERTIFICATIONS

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

Long Island Certification IDs

575 Broad Hollow Rd, Melville, NY 11747

New York Certification #: 10478 Primary Accrediting Body

New Jersey Certification #: NY158

Pennsylvania Certification #: 68-00350

Connecticut Certification #: PH-0435

Maryland Certification #: 208

Rhode Island Certification #: LAO00340

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE SUMMARY

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

Lab ID	Sample ID	Matrix	Date Collected	Date Received
704710001	1-DW-@ROOM 12 (L)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710002	2-DW-@ROOM 12 (R)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710003	3-DW-@ROOM 17-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710004	4-DW-@ROOM 30 (L)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710005	5-DW-@ROOM 30 (R)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710006	6-KC-KITCHEN (L)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710007	7-KC-KITCHEN (R)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710008	8-DW-@GYM (L)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710009	9-DW-@GYM (R)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710010	10-WC-@PRINCIPAL-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710011	11-NS-NURSE OFFICE-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710012	12-NS-NURSE OFFICE(LAV)-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710013	13-TL-FACUTLY ROOM-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710014	16-WC-@ROOM 69-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710015	17-WC-@ROOM 48-FD	Drinking Water	11/11/16 06:30	11/12/16 10:00
704710016	FIELD BLANK	Drinking Water	11/11/16 06:30	11/12/16 10:00

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

SAMPLE ANALYTE COUNT

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
704710001	1-DW-@ROOM 12 (L)-FD	EPA 200.8	AEG	1	PACE-MV
704710002	2-DW-@ROOM 12 (R)-FD	EPA 200.8	AEG	1	PACE-MV
704710003	3-DW-@ROOM 17-FD	EPA 200.8	AEG	1	PACE-MV
704710004	4-DW-@ROOM 30 (L)-FD	EPA 200.8	AEG	1	PACE-MV
704710005	5-DW-@ROOM 30 (R)-FD	EPA 200.8	AEG	1	PACE-MV
704710006	6-KC-KITCHEN (L)-FD	EPA 200.8	AEG	1	PACE-MV
704710007	7-KC-KITCHEN (R)-FD	EPA 200.8	AEG	1	PACE-MV
704710008	8-DW-@GYM (L)-FD	EPA 200.8	AEG	1	PACE-MV
704710009	9-DW-@GYM (R)-FD	EPA 200.8	AEG	1	PACE-MV
704710010	10-WC-@PRINCIPAL-FD	EPA 200.8	AEG	1	PACE-MV
704710011	11-NS-NURSE OFFICE-FD	EPA 200.8	AEG	1	PACE-MV
704710012	12-NS-NURSE OFFICE(LAV)-FD	EPA 200.8	AEG	1	PACE-MV
704710013	13-TL-FACUTLY ROOM-FD	EPA 200.8	AEG	1	PACE-MV
704710014	16-WC-@ROOM 69-FD	EPA 200.8	AEG	1	PACE-MV
704710015	17-WC-@ROOM 48-FD	EPA 200.8	AEG	1	PACE-MV
704710016	FIELD BLANK	EPA 200.8	AEG	1	PACE-MV

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

Sample: 1-DW-@ROOM 12 (L)-FD		Lab ID: 704710001		Collected: 11/11/16 06:30		Received: 11/12/16 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		11/21/16 21:56	7439-92-1		
Sample: 2-DW-@ROOM 12 (R)-FD		Lab ID: 704710002		Collected: 11/11/16 06:30		Received: 11/12/16 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		11/21/16 21:59	7439-92-1		
Sample: 3-DW-@ROOM 17-FD		Lab ID: 704710003		Collected: 11/11/16 06:30		Received: 11/12/16 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		11/21/16 22:14	7439-92-1		
Sample: 4-DW-@ROOM 30 (L)-FD		Lab ID: 704710004		Collected: 11/11/16 06:30		Received: 11/12/16 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	<1.0	ug/L	1.0	1		11/21/16 22:22	7439-92-1		
Sample: 5-DW-@ROOM 30 (R)-FD		Lab ID: 704710005		Collected: 11/11/16 06:30		Received: 11/12/16 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	9.0	ug/L	1.0	1		11/21/16 22:25	7439-92-1		
Sample: 6-KC-KITCHEN (L)-FD		Lab ID: 704710006		Collected: 11/11/16 06:30		Received: 11/12/16 10:00		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8							
Lead	5.1	ug/L	1.0	1		11/21/16 22:28	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

Sample: 7-KC-KITCHEN (R)-FD		Lab ID: 704710007	Collected: 11/11/16 06:30	Received: 11/12/16 10:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	11.5	ug/L	1.0	1		11/21/16 22:31	7439-92-1	
Sample: 8-DW-@GYM (L)-FD		Lab ID: 704710008	Collected: 11/11/16 06:30	Received: 11/12/16 10:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	1.5	ug/L	1.0	1		11/21/16 22:34	7439-92-1	
Sample: 9-DW-@GYM (R)-FD		Lab ID: 704710009	Collected: 11/11/16 06:30	Received: 11/12/16 10:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		11/21/16 22:37	7439-92-1	
Sample: 10-WC-@PRINCIPAL-FD		Lab ID: 704710010	Collected: 11/11/16 06:30	Received: 11/12/16 10:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	<1.0	ug/L	1.0	1		11/21/16 22:46	7439-92-1	
Sample: 11-NS-NURSE OFFICE-FD		Lab ID: 704710011	Collected: 11/11/16 06:30	Received: 11/12/16 10:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	3.0	ug/L	1.0	1		11/21/16 22:49	7439-92-1	
Sample: 12-NS-NURSE OFFICE(LAV)-FD		Lab ID: 704710012	Collected: 11/11/16 06:30	Received: 11/12/16 10:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8						
Lead	2.8	ug/L	1.0	1		11/21/16 22:51	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

ANALYTICAL RESULTS

Project: SP BOE GRANT SCHOOL 16-27004B
Pace Project No.: 704710

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: 13-TL-FACUTLY ROOM-FD **Lab ID: 704710013** Collected: 11/11/16 06:30 Received: 11/12/16 10:00 Matrix: Drinking Water

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		11/21/16 22:54	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: 16-WC-@ROOM 69-FD **Lab ID: 704710014** Collected: 11/11/16 06:30 Received: 11/12/16 10:00 Matrix: Drinking Water

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		11/21/16 22:57	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: 17-WC-@ROOM 48-FD **Lab ID: 704710015** Collected: 11/11/16 06:30 Received: 11/12/16 10:00 Matrix: Drinking Water

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		11/21/16 23:00	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

Sample: FIELD BLANK **Lab ID: 704710016** Collected: 11/11/16 06:30 Received: 11/12/16 10:00 Matrix: Drinking Water

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8

Lead	<1.0	ug/L	1.0	1		11/21/16 23:03	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

QC Batch: 4695

Analysis Method: EPA 200.8

QC Batch Method: EPA 200.8

Analysis Description: 200.8 MET No Prep Drinking Water

Associated Lab Samples: 704710001, 704710002

METHOD BLANK: 23739

Matrix: Water

Associated Lab Samples: 704710001, 704710002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	11/21/16 20:40	

LABORATORY CONTROL SAMPLE: 23740

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.0	96	85-115	

MATRIX SPIKE SAMPLE: 23742

Parameter	Units	704971021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.7	2	4.0	118	70-130	

SAMPLE DUPLICATE: 23741

Parameter	Units	704971021 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	1.7	1.6	4	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALIFIERS

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

LABORATORIES

PACE-MV Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: SP BOE GRANT SCHOOL 16-27004B

Pace Project No.: 704710

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
704710001	1-DW-@ROOM 12 (L)-FD	EPA 200.8	4695		
704710002	2-DW-@ROOM 12 (R)-FD	EPA 200.8	4695		
704710003	3-DW-@ROOM 17-FD	EPA 200.8	4697		
704710004	4-DW-@ROOM 30 (L)-FD	EPA 200.8	4697		
704710005	5-DW-@ROOM 30 (R)-FD	EPA 200.8	4697		
704710006	6-KC-KITCHEN (L)-FD	EPA 200.8	4697		
704710007	7-KC-KITCHEN (R)-FD	EPA 200.8	4697		
704710008	8-DW-@GYM (L)-FD	EPA 200.8	4697		
704710009	9-DW-@GYM (R)-FD	EPA 200.8	4697		
704710010	10-WC-@PRINCIPAL-FD	EPA 200.8	4697		
704710011	11-NS-NURSE OFFICE-FD	EPA 200.8	4697		
704710012	12-NS-NURSE OFFICE(LAV)-FD	EPA 200.8	4697		
704710013	13-TL-FACUTLY ROOM-FD	EPA 200.8	4697		
704710014	16-WC-@ROOM 69-FD	EPA 200.8	4697		
704710015	17-WC-@ROOM 48-FD	EPA 200.8	4697		
704710016	FIELD BLANK	EPA 200.8	4697		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.

CHAIN-OF-CUSTODY / Analytical Request Document



The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: 2 of 2

Section A		Section B		Section C	
Required Client Information:		Required Project Information:		Invoice Information:	
Company: Omega Environmental		Report To: Michael Levy		Attention: Acct's Payable	
Address: 280 Huyler Street		Copy To: mikel@omega-env.com		Company Name: Omega Environmental	
South Hackensack, NJ 07606		lab@omega-env.com		Address: 280 Huyler Street	
Email To: lab@omega-env.com		Purchase Order No.:		Pace Quote Reference:	
Phone: 201.489.8700		Project Name: SP BOE Grant School		Pace Project Manager:	
Requested Due Date/TAT: 5 Day Tat		Project Number: 16-27004B		Pace Profile #:	
				REGULATORY AGENCY	
				NPDES	
				GROUND WATER	
				UST	
				RCRA	
				OTI	
				X DRINKING WATER	
				Site Location	
				STATE: NJ	

ITEM #	Section D	Valid Matrix Codes MATRIX	Required Client Information	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		# OF CONTAINERS	Preservatives	Y/N	Requested Analysis Filtered (Y/N)	Temp in °C	Received on	Sealed	Custody	Samples Intact (Y/N)
						COMPOSITE START	COMPOSITE END/GRAB									
						DATE	TIME									
1	13 TL	FD	Faculty Room	DW G	G	11/16/16	4:34	1	Unpreserved							
2	14 DW	FD	@ Room 65(L)	DW G	G	11/16/16		1	H ₂ SO ₄	X						
3	15 DW	FD	@ Room 65(R)	DW G	G	11/16/16		1	HNO ₃	X						
4	16 WC	FD	@ Room 69	DW G	G	11/16/16		1	NaOH	X						
5	17 WC	FD	@ Room 48	DW G	G	11/16/16		1	HCl	X						
6	18	0	Field Blank	DW G	G	11/16/16		1	Unpreserved							
7	19	0		DW G	G	11/16/16		1	H ₂ SO ₄	X						
8	20	0		DW G	G	11/16/16		1	HNO ₃	X						
9	21	0		DW G	G	11/16/16		1	NaOH	X						
10	22	0		DW G	G	11/16/16		1	Methanol	X						
11	23	0		DW G	G	11/16/16		1	Other	X						
12	24	0		DW G	G	11/16/16		1	Lead in Water	X						

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	Kyle Brown	11/16/16	10:00	Chris Gail	11/16/16	10:00	
	Chris Gail	11/16/16	11:00				
	Chris Gail	11/16/16	10:00				Box N Y

SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER: Kyle Brown	Omega Environmental
SIGNATURE of SAMPLER: <i>[Signature]</i>	(MM/DD/YYYY): 11/16/16



Sample Condition Upon Receipt

WO#: 704710
PM: EMH Due Date: 11/21/16
CLIENT: OES

Client Name: OES

Courier: Fed Ex UPS USPS Client Commercial Pace Other

Tracking #: 7846 2054 6370

Custody Seal on Cooler/Box Present: yes no X no Seals intact: yes no

Packing Material: Bubble Wrap Bubble Bags None Other Box

Thermometer Used: TH077 TH078 Type of Ice: Wet Blue None Samples on ice, cooling process has begun

Cooler Temperature:

Date and Initials of person examining contents: 11/21/16 LSP

Table with 16 rows of inspection items and checkboxes. Items include Chain of Custody Present, Chain of Custody Filled Out, Chain of Custody Relinquished, Sampler Name & Signature on COC, Samples Arrived within Hold Time, Short Hold Time Analysis (<72hr), Rush Turn Around Time Requested, Sufficient Volume, Correct Containers Used, Containers Intact, Filtered volume received for Dissolved tests, Sample Labels match COC, All containers needing preservation have been checked, Samples checked for dechlorination, Headspace in VOA Vials (>6mm), Trip Blank Present, Trip Blank Custody Seals Present.

Client Notification/ Resolution: Field Data Required? Y / N
Person Contacted: Date/Time:
Comments/ Resolution:

* PM (Project Manager) review is documented electronically in LIMS.